



Milton Roy Company  
201 Ivyland Road  
Ivyland, PA 18974  
Phone: 215-441-0800  
Fax: 215-441-8620

## Pump Test Report

Customer	PREMIER EQUIPMENT (BILL-TO) -FCD WIL-	Model	MBH101-8HPFCBM4SEST11NN22
P.O. Number	P52029	Serial Number	3597224-1
Order Number	2283272	Date	8/9/2013 8:31:10 AM
Reference	NONE	Operator	B. GARTNER

### Rated Flow

7.800 GPH @ 3150.00 PSI
0.130 GPM @ 3150.00 PSI
29.526 LPH @ 217.19 bar
0.492 LPM @ 217.19 bar
29.526 LPH @ 221.47 kg/sq. cm.
29.526 LPH @ 2214669.18 kg/sq. m.
0.029 M <sup>3</sup> /Hr. @ 21718.46 KPa

### Test Results

\* Tested with water, adequate flooded suction.

Average Flow (GPH)	9.7698
Average Flow (LPH)	36.9824
Repetative Accuracy (%)	99.8875
Result	PASSED

### Drive Data

Horsepower	Test Motor
Motor Voltage	460 V
Supply Type	Three Phase
Frequency	60 Hz

## Certificate of Conformance

This is to certify that the product(s) contracted by the purchase order have been manufactured, processed, inspected, tested and conforms in all respects to Milton Roy specifications.

Test Technician: B. GARTNER

Signature: